

FSR SW-DB Data Only Device Box Installation Instructions

244 Bergen Boulevard, Woodland Park, NJ 07424, Phone: 973.785.4347 - Fax: 973.785.4207

NOTICE: For installation by a qualified electrician in accordance with all national and local electrical codes and communications standards. Adhere to the following instructions and any instructions included with the individual raceway components.

1. Install box chassis to raceway base. End kit & raceway base edge must be installed first if mounting box on raceway base end.
2. Make wiring connections as required, and install decorator style units to mounting plate.
3. Install cover plate and end caps with supplied screws.

Classification; CTS/DTS 3.102 Flushfloor, 3.103 Onfloor, 6.101.1 Dry-Treatment Only, 6.2.6 10J Impact
6.102.3 1,000 N Small Surface Load, 6.4.1 Non-Flame Propagating
IP41; Min Storage Temp - 25 °C; Installation and Application Temp - 15 °C to 60 °C

CAUTION: Ensure Edge Of Raceway Cover Is Deburred.

