

# FSR SW-DB-SE2P2D Installation Instructions

244 Bergen Boulevard, Woodland Park, NJ 07424, Phone: 973.785.4347 - Fax: 973.785.4207

**NOTICE:** For installation by a qualified electrician in accordance with all National and Local Electrical Codes and communication standards. Adhere to the following instructions and any instructions included with the individual Raceway components.

1. Install Box Chassis onto installed Raceway Base.
2. Make wiring connections as required, and per customer specs, install Decorator Style Devices and/or Decorator Style Brush Inserts as required.
3. Install Box Cover.

Classification; CTS/DTS 3.102 Flushfloor, 3.103 Onfloor, 6.101.1 Dry-Treatment Only, 6.2.6 10J Impact  
6.102.3 1,000 N Small Surface Load, 6.4.1 Non-Flame Propagating  
IP41; Min Storage Temp - 25°C; Installation and Application Temp - 15°C to 60°C

**CAUTION:** Ensure edge of Raceway Cover is deburred.

