

FSR Symphony Connect Installation Instructions


244 Bergen Boulevard, Woodland Park, NJ 07424, Phone: 973.998.2300 - Fax: 973.785.4207

NOTICE: For installation in accordance with all national and local electrical codes and communications standards.

Symphony Connect systems are not for permanent installation as part of the building structure and not for mounting in a permanently installed furnishing such as a fixed countertop. Protect all cords from pedestrian traffic. Symphony Connect table boxes and interconnecting cords shall not be located on floor surfaces.

Installation:


1. Mount Symphony Table Boxes per included installation instructions.
2. Route and secure Table Box cords away from hinges, pinch points or moving parts. Provided cable clips may be used and are highly recommended for cable management.



3. If extra cord length is required between Table Boxes, 3' and 6' length cords can be added between units.


⚠ Caution: Total line cord length **CANNOT** exceed 50'. Use below table to calculate total length.

System Location	Model Number	System Cord Length for Calculation
Starter or 1st Unit	SYM-CN-CL-1ST SYM-CN-UT-1ST SYM-CN-OT-1ST SYM-CN-IN-1ST	9' Input Cord 3.5' Output Cord
Middle Units (Mult per System)	SYM-CN-CL-MID SYM-CN-UT-MID SYM-CN-OT-MID SYM-CN-IN-MID	3.5' Input Cord 3.5' Output Cord
End Unit	SYM-CN-CL-END SYM-CN-UT-END SYM-CN-OT-END SYM-CN-IN-END	3.5' Input Cord
Between Unit Extension Cord(s)	SYM-CN-3EXT SYM-CN-6EXT	3' Cord 6' Cord




SYM-CN-CL-1ST
SYM-CN-UT-1ST
SYM-CN-OT-1ST
SYM-CN-IN-1ST
12.5' Total Cord Length


⚠ CAUTION: Risk of Electric Shock. Symphony Connect 1ST unit is not to be connected to another relocatable power tab, FPDU, or extension cord.



SYM-CN-CL-MID
SYM-CN-UT-MID
SYM-CN-OT-MID
SYM-CN-IN-MID
7' Total Cord Length



SYM-CN-CL-END
SYM-CN-UT-END
SYM-CN-OT-END
SYM-CN-IN-END
3.5' Total Cord Length



SYM-CN-3EXT
SYM-CN-6EXT
3' or 6' Cord Length